

10 Point Scaffolding Safety Inspection

Please check the following conditions and indicate whether the scaffolding was in a safe or unsafe condition.

	<u>YES</u>	<u>NO</u>
1. Ladder provided for access, secured and 3 ft. above platform?	_____	_____
2. Planking is 2X10 scaffold grade free of cracks, defects, and excessive debris?	_____	_____
3. Top rail, mid rail and end rails secure and provided over 7 ½ ft.?	_____	_____
4. Full solid planking (3 boards) provided above 7 ½ ft. with opening under back railing not exceeding 10" maximum?	_____	_____
5. Space between building and platform not exceeding 16"?	_____	_____
6. Single plank permitted only on platforms up to 4 ft. high?	_____	_____
7. Platform slopes do not exceed 2 ft. vertically to 10 ft. horizontally?	_____	_____
8. Planking overhangs ledger or support 6" minimum and 18" max.?	_____	_____
9. All support leg base plates resting on dirt are secured to a 2"X10"X10" wooden base or 1 1/8"X10"X10" exterior grade plywood?	_____	_____
1. Scaffold ties to building with double looped #12 or single looped #10 Iron wire not to exceed 30 ft. horizontally and 26 ft. intervals vertically?	_____	_____

Inspectors Name

Date

Inspectors Company

Project/Job Site